



6435 State Highway 19 N PO Box 1385
Athens, Texas 75752 Athens, Texas 75751
903-675-8466 phone 903-677-5651 fax

Dear Customer,

The Texas Commission on Environmental Quality (TCEQ) has notified BETHEL-ASH WSC WALTON PLANT TX 1070243 that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes to be 0.080 milligrams per liter (mg/L) based on the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in quarter one 2024 of 0.090 mg/L for DBP2-01.

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

- Reducing age of water within the storage facilities by increasing periodic flushing
- Close monitoring of chlorine levels
- Review ways to improve seasonal changes to chlorine levels

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Cody Rayburn General Manager at 903-675-8466.

Posted/Delivered on: 04/12/2024